

Monthly Overflow Report

Date Range: March, 2009

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08102017	03/04/09	03/04/09	0.5 hours	0.00002	0.00	Grit/Debris	2600 Clarksville Pk. Line Cleaned
000	17112117	03/21/09	03/21/09	1.5 hours	0.00003	0.00	Grit/Debris	1200 Banbury Row. Line Cleaned
000	10408036	03/24/09	03/24/09	1.5 hours	0.0002	0.00	Grit/Debris	2001 Belcourt Ave. Line Cleaned
000	14914001	03/24/09	03/24/09	3 hours	0.004	0.00	Grit/Debris	1621 Bridge Crestway. Line Cleaned
000	16106051	03/28/09	03/28/09	1 hours	0.002	0.00	Grit/Debris	729 McMurray Dr. Line Cleaned

Monthly Overflow Report

Date Range: March, 2009

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04312035	03/30/09	03/30/09	1.5 hours	0.0003	0.00	Grit/Debris	200 Rio Vista Dr. Line Cleaned

Monthly Overflow Report

Date Range: March, 2009

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09011003	03/15/09	03/16/09	29.5 hours	0.15	0.00	Line Break	510 Basswood Ave. 36-inch line collapse repaired by contractor.
000	05008006	03/23/09	03/23/09	3.5 hours	0.0003	0.00	Grit/Debris	3504 Dickerson Rd. Line Cleaned
104	Whites Creek PS	03/14/09	03/14/09	10.75 hours	0.91	1.20	Rainfall	Inflow/infiltration. Station operating at rated capacity.
104	Whites Creek PS	03/16/09	03/16/09	9.33 hours	0.834	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/17/09	03/17/09	3.17 hours	0.404	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/18/09	03/18/09	20.33 hours	1.548	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/19/09	03/19/09	24 hours	1.05	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/20/09	03/20/09	17.75 hours	0.483	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/21/09	03/21/09	11.58 hours	0.142	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/27/09	03/27/09	6.58 hours	0.352	0.54	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	03/28/09	03/28/09	0.33 hours	0.044	0.49	Rainfall	Inflow/infiltration. Station at rated capacity.
104	Whites Creek PS	03/29/09	03/29/09	0.33 hours	0.047	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/30/09	03/30/09	0.42 hours	0.044	0.00	Other/not listed	Peak influent rate exceeds station rated capacity.
104	Whites Creek PS	03/31/09	03/31/09	0.83 hours	0.048	0.07	Rainfall	Inflow/infiltration. Station at rated capacity.
114	Davidson Branch PS	03/14/09	03/14/09	1.92 hours	0.047	1.21	Rainfall	Inflow/infiltration. Station operating at rated capacity.
145	Joelton PS	03/14/09	03/14/09	4 hours	0.005	1.24	Rainfall	Inflow/infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: March, 2009

Satellite Systems

#	Overflow Name	Start Date	End Date	Duration	Volume	Rainfall	Overflow Cause	Remarks
					(mg)			

Sanitary Sewer Overflows

111	Brentwood PS	03/14/09	03/14/09	8.42 hours	0.278	1.06	Rainfall	Inflow/infiltration. Station operating at rated capacity.
-----	--------------	----------	----------	------------	-------	------	----------	---